WTCI-516-P 35

1 WTC, OUTDOOR ... CLIP

THE PORT AUTHORITY OF NY & NJ
OFFICE OF ENVIRONMENTAL POLICY AND MANAGEMENT SURVEY # _____
SAMPLE DATA SHEET

FACILITY: WORLD TRADE CENTER
LOCATION: 80TH FLOOR
AREA DESCRIPTION: SECONDARY M/C ROOM
REASON FOR SAMPLING: DUST CONDITION
BUILDING: 1
FLOOR: 80

SAMPLE NUMBER:	SAMPLE DESCRIPTION:
WTC 141168 LAB #	DUST LIKE MATERIAL COLLECTED FROM THE FLOOR AREA ADJACENT TO CAR # 15A EQUIPMENT IN THE SECONDARY ROOM. (AREA = 100 CM², AS PER ASTM-D5755-95)
WTC 141169 LAB #	DUST LIKE MATERIAL COLLECTED FROM THE FLOOR AREA ADJACENT TO CAR # 14A EQUIPMENT IN THE SECONDARY ROOM. (AREA = 100 CM², AS PER ASTM-D5755-95)
LAB #	
LAB #	
LAB #	
LAB #	
LAB #	
LAB #	
LAB #	
LAB #	

PLAINTIFF'S EXHIBIT PX-771

PROJECT TITLE: N/A
CONTRACT NUMBER: _____ SAMPLE TYPE: __ ALTF __ RESURVEY √ SPECIAL
JOB NUMBER: NA

drawing
ANALYSE AS PER ASTM - D5755 - 95

PORT AUTHORITY FIELD REPRESENTATIVES: P. NEGRON, U. MEHTA DATE: 09/09/97

DISTRIBUTION WHITE COPY—OEPM LAB CANARY COPY—OEPM PROJECT BINDER
PINK COPY —OEPM FIELD OFFICE

PA 377
10/

Westmont, NJ (19) 858-1280 | Piscataway, NJ (908) 981-0550 | Carle Place, NY (516) 997-7251 | Smyrna, GA (404) 333-6066 | Melbourne, FL (407) 253-4224 | Ann Arbor, MI (313) 668-6810 | San Mateo, CA (415) 570-5401

EMSL

Thursday, April 10, 1997

Port Authority of NY & NJ
241 Erie St. Room 210
Jersey City, NJ 07310
Phone: (201) 216-2774
Fax: (201) 216-2158

Project: World Trade Center / 80th Floor / Secondary n/c Room / Dust Condition / Bldg. #1 / Floor: 80
Attention: David Platt / Uday Mehta
Ref Number: NY972037
Page: 1 of 1

TEM Quantative Micro Vac ASTM Method D5755-55

SAMPLE ID	AREA SAMPLED	ASBESTOS DETECTED	CONCENTRATION (str. / sq. cm.)
WTC 141168	100 sq. cm.	Chrysotile	84,505
WTC 141169	100 sq. cm.	Chrysotile	38,938

Edward R. Cahill
Laboratory Director

THE PORT AUTHORITY OF NY & NJ
OFFICE OF ENVIRONMENTAL POLICY AND MANAGEMENT SURVEY # _____
SAMPLE DATA SHEET

FACILITY: WTC
LOCATION: 2 WTC - ME22
AREA DESCRIPTION: CHANDELIERS
REASON FOR SAMPLING: _____
BUILDING: 2
FLOOR: ME22

SAMPLE NUMBER:	SAMPLE DESCRIPTION:
WTC 140145	DUST SAMPLE COLLECTED FROM SECTION OF CHANDELIERS SAMPLE AREA 6" X 7"
LAB #	
WTC 140146	DUST SAMPLE COLLECTED FROM SECTION OF CHANDELIER SAMPLE AREA 6" X 9"
LAB #	
LAB #	
LAB #	
LAB #	
LAB #	
LAB #	
LAB #	
LAB #	
	ANALYSE FOR SETTLED DUST ASTM-5755-95
LAB #	

PROJECT TITLE: MA
CONTRACT NUMBER: N/A SAMPLE TYPE: ___ ALT.
JB NUMBER: N/A ___ RESURVEY
___ SPECIAL

drawing

PORT AUTHORITY FIELD REPRESENTATIVES: E. DAMBRONIG, U. MEHTA DATE: 03/03/97

DISTRIBUTION: WHITE COPY—OEPM LAB; CANARY COPY—OEPM PROJECT BINDER
PINK COPY—OEPM FIELD OFFICE

PA 3739
10-93

Westmont, NJ (609) 858-1260 | Piscataway, NJ (908) 981-0550 | Carle Place, NY (516) 997-7251 | Smyrna, GA (404) 333-6066 | Melbourne, FL (407) 253-4224 | Ann Arbor, MI (313) 668-8810 | San Mateo, CA (415) 570-5401

EMSL

Thursday, February 20, 1997

Port Authority of NY & NJ
241 Erie Street, Room 210
Jersey City, NJ 07310
Phone: (201) 216-2774
Fax: (201) 216 - 2158

Project: WTC / 2 WTC - Mezz / Chandeliers
Attention: David Platt
Ref Number: NY971234
Page: 1 of 1

TEM Quantative Micro Vac ASTM Method D5755-55

SAMPLE ID	AREA SAMPLED	ASBESTOS DETECTED	CONCENTRATION (str. / sq. cm.)
WTC 140145	18 sq. inches	None Detected	<252.97
WTC 140146	18 sq. inches	None Detected	<252.97

Edward R. Cahill
Laboratory Director

ACCREDITATIONS: AIHA #381, NVLAP #1048 and NY STATE ELAP #11506